

LANDLORD/HOME OWNER GAS SAFETY RECORD

This inspection is for gas safety purposes only in accordance with the current edition of the Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has not been carried out.

GAS INSTALLER: (Trading Title) <i>COLIN ROBERTSON</i>		Gas Safe Register No: <i>157664</i>
Name: <i>C. ROBERTSON</i>	Gas Installer Ref. No: <i>A.B.</i>	
Address: <i>19 LEITCHTON CREST</i>	Date of Issue: <i>15/2/24</i>	
Post code: <i>PO30 5ZG</i>	Time of Issue:	
Tel: <i>07710448500</i>	Engineers Name: (print) <i>C. ROBERTSON</i>	

TENANT/HOME OWNER DETAILS

Tenant/Home Owner* Name:	
Property Address: <i>8. PARKSIDE AVENUE</i>	
<i>TONGHAM. YORK</i>	
Post Code	Tel:
Tenant/Home Owner* present during inspection	YES/NO

LANDLORD/AGENT DETAILS (if applicable)

Landlord/Agent* Name: <i>HOAM BARNETT LETTING</i>	
Address: <i>58 GREYFRIAR</i>	
<i>YORK</i>	
Post Code	Tel: <i>011611</i>
Landlord/Agent* present during inspection	YES/NO

APPLIANCE DETAILS					INSPECTION DETAILS					FLUE TEST					RESULTS				
LOCATION	MAKE	MODEL	TYPE	Flue Type e.g. CF or RS	Operating Pressure Mbar	Heat Input Kw	Safety Device Correct Operation Yes/No	Ventilation Adequate Yes/No	CO Alarm fitted Yes/No	CO Alarm tested Pass/Fail	Flue Flow Test Pass/Fail	Spillage Test Pass/Fail	Termination Satisfactory Yes/No	Visual Condition Pass/Fail	Combustion Performance Reading CO ₂ %	CO2 Ratio / CO2 CO	Appliance Safe To Use Yes/No	Landlord's Appliance Yes/No	Inspected Yes/No
1	Vokera	UNICA 32	HE	RS	18.4	1	YES	N/A	YES	PASS	PASS	PASS	CO ₂ 9.0	PASS	8.4/9.24		YES	YES	YES
2																			
3																			
4																			
5																			

DETAILS OF ANY FAULTS			REMEDIAL ACTION TAKEN			DETAILS OF WORK CARRIED OUT			LABEL & WARNING NOTICE ISSUED	
1	<i>No CO Alarm</i>		<i>1</i>	<i>Fitted CO Alarm</i>					Yes	NO
2	<i>Boiler showing signs of age compared in size to boiler chamber</i>									
3										
4										
5										

Outcome of gas installation pipework visual inspection?	<i>Pass / Fail / NA</i>		This Safety Record is issued by Gas Installer: (SIGNED)
Outcome of gas supply pipework visual inspection?	<i>Pass / Fail / NA</i>		
Is the Emergency Control Valve access satisfactory?	<i>Pass / Fail / NA</i>		
Outcome of gas tightness test?	<i>Pass / Fail / NA</i>		
Is the Protective Equipotential bonding satisfactory?	<i>Pass / Fail / NA</i>		
Received on behalf of Landlord / Home Owner: (SIGNED)			ATTENTION Next safety check due by: <i>15/2/25</i>
Tenant/Landlord/Agent/Home Owner*			
Number of appliances tested: <i>ONE</i>			
Date: <i>15/2/24</i>			

To re-order quote code 663010-NUM

Copies: White - Landlord/Agent/Home Owner

Green - Registered Gas Installer

Pink - Tenant

* delete as applicable

1944031

ARCTIC
HAYES