

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

FT/EIC 5018000001024



Client Details

Client	Alison Elsome	Installation	Rental Property, 52 Third Avenue, York, YO31 0TY
Address	Kirkside Cottage Appleton le Moors York	Address	52 Third Avenue York
Postcode	YO626TE	Postcode	YO310TY

Details of the Installation

Description of premises Residential or Similar ☒ Commercial ☐ Industrial ☐ Date of original installation 1970/80s/2021

Installation is New ☐ Addition ☐ Alteration ☒ Records Available Yes ☒ No ☐ RCD Risk assessment attached ☐

Description of the installation

ex local authority re-wire done 40/50 years ago. new ring circuits added 2021

Extent of the installation covered by this certificate

consumer unit and all circuits connected to it tested. wires concealed in walls and ceilings were not inspected

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)

upstairs socket outlets lower than 450mm from floor

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate

None

Declaration for Design, Construction, Inspection and Testing (for sole person responsibility)

I being the person responsible for design, construction, inspection and the test of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which i have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022 except for the departures, if any, listed below. The extent of liability of the signatory or the signatories is limited to work described in Section 2 as subject of this certificate.

For the DESIGN / CONSTRUCTION / INSPECTION & TEST of the installation:

Company	Backhaul Sales Services Limited	Position	Director
Inspector Name	Paul Elsome	Date	04/08/2024
Address	Kirkside Cottage York, North Yorkshire YO62 6TE	Scheme No.	50180
		Branch No.	
		Signature	Paul Elsome

Reviewed By		Reviewed By	
Reviewed By Date		Signature	

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than 5 years

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

FT/EIC 5018000001024



Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S ☒ TN-C-S ☐ TT ☐ Other ☐ If Other please specify N/A

Number & Type of live conductors AC ☒ DC ☐ No. of phases 1 No. of wires 2

Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

Nominal voltage, U/U₀ ⁽¹⁾ 230 v Nominal frequency, f⁽¹⁾ 50 Hz Confirmation of polarity ☒

Prospective fault current, I_{pf} ⁽²⁾ 1.2 kA External loop impedance, Z_e ⁽²⁾ 0.21 Ω

Supply Protective Device BS (EN) 1361 Type 2 Rated Current 63 A

No. of Additional Supplies none

Particulars of Installation at the Origin

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) N/A
Location N/A Electrode resistance to earth N/A Ω **Means of Earthing** Distributors facility ☒ Installation Earth Electrode ☐
Maximum Demand (load) 63 Amps ☒ KVA ☐

Main Protective Conductors	Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper	16 mm ²	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input type="checkbox"/>
Protective Bonding Conductor	Copper	10 mm ²	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input type="checkbox"/>

Main Supply Conductor	Material	csa	(connection / continuity) (✓) or Value	(✓) or Value
	Copper	16 mm ²	Water installation <input checked="" type="checkbox"/>	To structural steel <input type="checkbox"/>
Main Switch	Location	on wall in understairs cupboard	Gas installation pipes <input checked="" type="checkbox"/>	To lightning protection <input type="checkbox"/>
			Oil installation pipes <input type="checkbox"/>	Other <input type="checkbox"/>

Fuse/device rating or setting 100 A Voltage rating 400 V BS(EN) 60947-3 No. of Poles 2 Current Rating 100 A
If RCD main switch: Rated residual operating current I_{Δn} mA Rated time delay ms Measured operating trip time ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

General condition Good

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory			Indicates the inspection is not applicable to a particular item		
		✓			N/A
1.0	Condition of consumer's intake equipment (visual inspection only)	✓	8.0	Circuits (Distribution and Final)	✓
2.0	Parallel or switched alternative sources of supply	N/A	9.0	Isolation and switching	✓
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	✓	10.0	Current-using equipment (permanently connected)	✓
4.0	Basic Protection	✓	11.0	Identification and notices	✓
5.0	Protective measure other than ADS	✓	12.0	Location(s) containing a bath or shower	✓
6.0	Additional protection	✓	13.0	Other special installations or locations	N/A
7.0	Distribution equipment	✓	14.0	Prosumer's low voltage electrical installation(s)	N/A

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) 1 schedules of circuit details and test results are attached

Inspector's Name: Paul Elsome

Signature

Paul Elsome

Date: 04/08/2024

FT/EIC 5018000001024



Client Name	Alison Elsome	Installation Address	Rental Property, 52 Third Avenue, York, YO31 0TY, 52 Third Avenue, York
Client Address	Kirkside Cottage, Appleton le Moors York	Postcode	YO310TY
Client Postcode	YO626TE		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation	
SPD Details: Type(s)*	T1 <input type="checkbox"/> T2 <input checked="" type="checkbox"/> T3+ <input type="checkbox"/> N/A <input type="checkbox"/>	Overcurrent protective device for the distribution circuit:	Supply to distribution board is from <input type="text"/>
Location	<input type="text" value="on wall understairs"/>	No. of phases	<input type="text" value="3"/> BS(EN) <input type="text" value="503"/> Type <input type="text" value="B"/> Rating <input type="text" value="16"/> A
Designation	<input type="text" value="DB1"/>	Nominal voltage	<input type="text" value="230"/> V RCD BS(EN) <input type="text" value="503"/> Type <input type="text" value="B"/> Rating <input type="text" value="16"/> IΔn mA
No. of ways	<input type="text" value="12"/>		

[illegible]

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic conduit, **C** PVC cables in non-metallic conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

for Domestic and Similar Premises up to 100 A

FT/EIC 5018000001024

[illegible]

Details of circuits and/or installed equipment vulnerable to damage when testing				Date(s) dead testing		18/07/2024		To		04/08/2024	
LED lights, smoke detectors				Date(s) live testing		04/08/2024		To		04/08/2024	
Test instrument serial number(s)		Loop impedance		3163149		Insulation resistance		3163149		Continuity	
Tested by: Name (capital letters)		PAUL ELSOME				Signature		Paul Elsome			
Position		Director		Date		04/08/2024					