

LANDLORD/HOME OWNER GAS SAFETY RECORD

This inspection is for gas safety purposes only in accordance with the current edition of the Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has not been carried out.

TENANT/HOME OWNER DETAILS

Tenant/Home Owner* Name:	
Property Address:	147. HESLINGTON LANE YORK
Post Code	
Tel:	
Tenant/Home Owner* present during inspection	YES/NO

LANDLORD/AGENT DETAILS (if applicable)

Landlord/Agent* Name:	ADAM BINKERT
Address:	58. GUYCLIFFE YORK
Tel:	611611
Post Code	
Landlord/Agent* present during inspection	YES/NO

GAS INSTALLER: (Trading Title)	C. ROBERTSON
Name:	C. ROBERTSON
Address:	19. LACROIX COURT HAWKESLEY PARK YORK YO30 5ZQ
Post code:	YO30 5ZQ
Tel:	07710448500
Gas Safe Register No:	157664
Gas Installer Ref. No :	A.B.
Date of Issue:	06/07/23
Time of Issue:	
Engineers Name: (print)	C. ROBERTSON

APPLIANCE DETAILS				INSPECTION DETAILS				FLUE TEST				RESULTS						
LOCATION	MAKE	MODEL	TYPE	Flue Type e.g. CF or RS	Operating Pressure Mbar	Heat Input Kw	Safety Device Correct Operation Yes/No	Ventilation Adequate Yes/No	CO Alarm fitted Yes/No	CO Alarm tested Pass/Fail	Flue Flow Test Pass/Fail	Spillage Test Pass/Fail	Termination Satisfactory Yes/No	Visual Condition Pass/Fail	Combustion Performance Reading CO ₂ / CO ₂ CO	Appliance Safe To Use Yes/No	Landlord's Appliance Yes/No	Inspected Yes/No
1 Kitchen	BAXI	445/4M	C/H	C.F.	12	—	YES	YES	YES	PASS	PASS	PASS	YES	PASS	0.001	YES	YES	YES
2																		
3																		
4																		
5																		

DETAILS OF ANY FAULTS				REMEDIAL ACTION TAKEN				DETAILS OF WORK CARRIED OUT				LABEL & WARNING NOTICE ISSUED	
1	CFM unit BATHS	UPPER PARTS	UPPER PARTS	UPPER PARTS	UPPER PARTS	UPPER PARTS	UPPER PARTS	UPPER PARTS	UPPER PARTS	UPPER PARTS	UPPER PARTS	YES	NO
2	GAS PIPE NOT SECURED IN WORK.												
3													
4													
5													

Outcome of gas installation pipework visual inspection?	Pass / Fail / NA
Outcome of gas supply pipework visual inspection?	Pass / Fail / NA
Is the Emergency Control Valve access satisfactory?	Pass / Fail / NA
Outcome of gas tightness test?	Pass / Fail / NA
Is the Protective Equipotential bonding satisfactory?	Pass / Fail / NA
This Safety Record is issued by Gas Installer: (SIGNED)	
Received on behalf of Landlord / Home Owner: (SIGNED)	
Tenant/Landlord/Agent/Home Owner*	
Number of appliances tested: 001	
Date: 06/07/23	