

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

REGISTERED BUSINESS DETAILS

Reg No:	302755
Company:	CBCL
Address:	111 RADLOW AVE Y6RM
Postcode:	Y610 3ST
Tel:	

INSPECTION/INSTALLATION ADDRESS

Name & Title:	DEBORAH ST
Address:	19 GEORGE ST WARRGATE Y6RM
Postcode:	
Tel:	

LANDLORD (OR AGENT) NAME & ADDRESS (if applicable)

Name & Title:	N/A
Address:	142 SHIPTON ROAD Y6RM
Postcode:	Y630 5RY
Tel:	

Number of appliances tested: TWO

APPLIANCE DETAILS

	Location	Make and Model	Type	Flue Type OF/RS/FL	Operating pressure in mbars or kW/h or Btu/h	Safety device(s) correct operation Yes/No/N/A	Spillage test Pass/Fail/N/A	Smoke pellet flue flow test Pass/Fail/N/A	Initial combustion analyser reading	Final combustion analyser reading	Satisfactory termination Yes/No/N/A	Flue visual condition Pass/Fail/N/A	Adequate ventilation Yes/No	Landlord's appliance Check Yes/No	Appliance serviced Yes/No	Appliance Safe to Use Yes/No
1	BED CUP	IDEAL i MINI	COMB	RS	30kW	YES	NA	NA	8.8	8.7	YES	PAS	YES	YES	YES	YES
2	MURCHEN	LARONA 4B	HOB	FL	2000B	YES	NA	NA	NA	NA	NA	NA	YES	YES	YES	YES
3																
4																
5																

For appliances not owned by the landlord the recorded 'Appliance Safe to Use' response is based on a visual check for obvious defects only

Gas Installation
Pipework:Satisfactory Visual
Inspection:Yes ☒ No ☐Emergency Control
Accessible:Yes ☒ No ☐Satisfactory Gas
Tightness Test:Yes ☒ No ☐Equipotential
Bonding Satisfactory:Yes ☒ No ☐

GIVE DETAILS OF ANY FAULTS

1	
2	
3	
4	
5	

OTHER COMMENTS OR OBSERVATIONS

NEXT GAS
SAFETY
CHECK DUE
BEFORE:

06/10/24

ISSUED BY (GAS ENGINEER)

Print Name: CBCL Licence No: 5053519
Signed: CBCL Issue Date: 06/10/2023

RECEIVED BY

Received By: MARCUS N/A
Signed: [Signature]
Print Name: [Signature]
No one present at time of visit ☐

WARNING NOTICE ISSUED Yes/No/NA	* WARNING TAG or LABEL FIXED Yes/No/NA

Approved Audible CO Alarms
Fitted & Located Correctly**:Yes ☒ No ☐ N/A ☐Testing of CO
Alarms Satisfactory:Yes ☒ No ☐ N/A ☐Smoke/Heat Alarms
Located & Fitted correctly**:Yes ☒ No ☐ N/A ☐