## **Domestic Landlord / Homeowner Gas Safety Record**

Date: 26th February 2024		Ref:				
Gas Safe Reg No:	628172	Serial no:	GAUK01070508			



Details of Registered Business		Details of Land	dlord / Homeowner (or agent where appropriate)	Details of Site			
Name:	GB Plumbing and Heating	Name:	Paula Kelday	Name:	Paula Kelday		
Address:	25 Westfield Place	Address:	8 The Leyes	Address:	8 The Leyes		
	York		York		York		
	North Yorkshire		North Yorkshire		North Yorkshire		
Postcode:	YO243HL	Postcode:	YO103PR	Postcode:	YO103PR		
Contact Number:	07376548084	Contact Number:		Contact Number:			

Appliance Details									Final check results			
	Location	Туре	Manufacturer	Model	Owned by	Landlord A	Appliance Inspected? Flue Type		Outcome of gas tightness test	Pass		
1	Kitchen	Boiler	Worcester	Greenstar 24i	Yes	Y	es	Room sealed	Is the main protective equipotential bonding satisfactory?	Yes		
								fan flue	Is the emergency control accessible?	Yes		
2	Kitchen	Gas hob	Unknown	Unknown	Yes	Y	es	Flueless	Satisfactory visual inspection of gas installation pipework?	Yes		
			CO alarm fitted and working?	Yes								
	Operating Pressure	Safety devices	Satisfactory	Visual condition of		Combustion			Notes			
	(mbars) or heat input (kW/h)	operating correctly?	Ventilation?	flue & termination.	checks.	analyser readi	ng. serviced?	to use?				
1	20.09 mbars	Yes	Yes	Pass	Pass	0.0012	No	Yes				
2	21.11 mbars	Yes	Yes	N/A	N/A	NA	No	Yes				

			Label & Warning	Combustion Performance Readings					
	Defects Identified	Remedial Work Details	Notice	Low			High		
				CO	CO <sup>2</sup>	Ratio	CO	CO <sup>2</sup>	Ratio
1			No	N/A	N/A	N/A	126	10.3	0.0012
2	Knobs falling off valves	NA	No	N/A	N/A	N/A	N/A	N/A	N/A

Next Increation to Due Deferrer	Record Issued By:			Received By:					
Next Inspection Is Due Before:	Signature:				Signature:				
		Aban		Name	Paula Kelsey				
26th February 2025					Position	Landlord	Date	26th February 2024	
	Gas Engineer	Greg Blasiak							
	Gas Safe Licence	5577192	Date	26th February 2024					

This record can be used to document the outcome of checks and tests required by The Gas Safety (Installation and Use) Regulations 1998 as amended by the Gas Safety (Installation and Use) (Amendment) Regulations 2018. Some of the outcomes are as a result of visual inspection only and are recorded where appropriate. Unless specifically recorded no detailed inspection of the flue lining, construction or integrity has been performed. Registered Business / engineer details can be checked at www.gassaferegister.co.uk or by calling 0800 408 5500.