

LANDLORD/HOME OWNER
GAS SAFETY RECORD

This inspection is for gas safety purposes only in accordance with the current edition of the Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has not been carried out.

GAS INSTALLER: (Trading Title) *C. Robertson*
Name: *C. Robertson* Gas Safe Register No: *157664*
Address: *19. Leighton Cliff* Gas Installer Ref. No: *R.A.*
Post code: *YO30 5ZG* Date of Issue: *6/6/24*
Tel: *07710448500* Engineers Name: (print) *C. Robertson*

TENANT/HOME OWNER DETAILS

Tenant/Home Owner* Name: _____
Property Address: *21. Rockingham Avenue*
TANG HALL YORK
Post Code _____ Tel: _____
Tenant/Home Owner* present during inspection *YES* / NO

LANDLORD/AGENT DETAILS (if applicable)

Landlord/Agent* Name: *Harman Bennett Leasing*
Address: *58. Gresham Street York*
Post Code _____ Tel: *611611*
Landlord/Agent* present during inspection *YES* / NO

APPLIANCE DETAILS				INSPECTION DETAILS				FLUE TEST				RESULTS						
LOCATION	MAKE	MODEL	TYPE	Flue Type e.g. CF or RS	Operating Pressure Mbar	Heat Input Kw	Safety Device Correct Operation Yes/No	Ventilation Adequate Yes/No	CO Alarm fitted Yes/No	CO Alarm tested (if fitted) Yes/No	Flue Flow Test Yes/No	Spillage Test Yes/No	Termination Satisfactory Yes/No	Visual Condition Yes/No	Combustion Performance Reading CO: CO2 Ratio / CO2 CO	Appliance Safe To Use Yes/No	Landlord's Appliance Yes/No	Inspected Yes/No
1	Kitchen	Hotpoint	HE	CO30	19	19	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	8.3/8.36	Yes	Yes	Yes
2																		
3																		
4																		
5																		
DETAILS OF ANY FAULTS				REMEDIAL ACTION TAKEN				DETAILS OF WORK CARRIED OUT				LABEL & WARNING NOTICE ISSUED						
1	Pipe not secured in wall											YES		NO				
2				2								YES		NO				
3				3				Maid re fitted CO alarm				YES		NO				
4				4								YES		NO				
5				5								YES		No				

DETAILS OF ANY FAULTS

REMEDIAL ACTION TAKEN

DETAILS OF WORK CARRIED OUT

LABEL & WARNING NOTICE ISSUED

1	Pipe not secured in wall																	YES	NO
2																		YES	NO
3	Mano re fitted CO alarm																	YES	NO
4																		YES	NO
5																		YES	No

Outcome of gas installation pipework visual inspection? *Pass / Fail / NA*

Outcome of gas supply pipework visual inspection? *Pass / Fail / NA*

Is the Emergency Control Valve access satisfactory? *Pass / Fail / NA*

Outcome of gas tightness test? *Pass / Fail / NA*

Is the Protective Equipotential bonding satisfactory? *Pass / Fail / NA*

This Safety Record is issued by Gas Installer: (SIGNED) *[Signature]*

Received on behalf of Landlord / Home Owner: (SIGNED)

Tenant/Landlord/Agent/Home Owner*

Number of appliances tested: *0/2*

Date: *15/6/25* NEXT GAS SAFETY CHECK DUE WITHIN 12 MONTHS

To re-order quote code 663010-NUM

Copies: White - Landlord/Agent/Home Owner

Green - Registered Gas Installer

Pink - Tenant

* delete as applicable

356827

