

Landlord Gas Safety Record

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.

Company /	Installe	r		Job Address						Customer / Landlord								
Engineer	Dave Elson					ne HMO												
Company	D E Gas Services					Address 12				C			C/O The Landlord Shop					
Address	ess 00					Green Dykes Lane				Address			19					
	Woodhead Close				York								Henconner Drive					
	Ossett					Post Code YO103HA							Leeds					
	West Yorkshire					101031#1							West Yorkshire					
Post Code	st Code WF59JJ					01012111100						Post Code	LS73NR					
Tel No.	el No. 07588579121											Tel. No	078660223	80				
Gas Safe Reg	Gas Safe Reg 523320																	
ID Card No. 4164277																		
Appliance D	Details						Inspec	tion Details										
Locatio	'n	Appliance Type	Make	Mode	21	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combusti Reading Ratio CO C ppm	on Low Combustio Reading O2 % Ratio CO CO ppm %		Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
1 Bathro	om	Combi Boiler	Vaillant	EcoTEC Pro 2 286/5		RS	Yes	Yes	20	27		9.0 NA NA N		Yes	Yes	NA	No	Yes
2																		
3																		
4																		
5																		
6																		
Defects / ld				Labels and Warning Notice Issued					CO Alarm(s) Smoke Alarm(s)									
1										NA		CO Alarm(s) f	itted	Yes	Smoke 4	Alarm(s) fitte	he	Yes
3														100	onione /			
4												CO Alarm(s) tested Pass Smoke Alarm(s) tested						Pass
5												and Satisfacto	ory	1 455	and Sati	sfactory		1 4 5 5
6																		
Emergency Co	ontrol Acc	essible Yes Gas	Tightness Satisfactory Yes	5	Comn	nents						<u> </u>						
Emergency Control Accessible Yes Gas Tightness Satisfactory Yes Comments Gas Installation Pipework Visual Inspection Satisfactory Yes																		
Equipotential Bonding Yes																		
Water quality/level of inhibitor acceptable Yes																		
NEXT INSPE	CTION DU	JE BEFORE	19-Aug-2025															
Signatures																		
Issued by:	Signed	B			Received S by:	Signed		Can				Date	16-Ju	ıl-2024				
Print Name		Dave Elson		Р	Print Name		Owner	Acces										