



LANDLORD / HOME OWNER GAS SAFETY RECORD

Report Ref No: 45C 4704970

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

REGISTERED BUSINESS DETAILS

Reg No:
Company: Abbey Plumbing + Heating
Address: 41 Kirkdate Road
Oswaldwick, York
Postcode: YO10 3NQ
Tel: 03876 492221

INSPECTION / INSTALLATION ADDRESS

Name & Title: Vacant
Address: ~~41 Kirkdate Road~~ 80 Thief Lane
York
Postcode: YO10 3HU Tel:

LANDLORD (OR AGENT) NAME & ADDRESS (if applicable)

Name & Title: Dawson
Address: 305 Hull Road
York
Postcode: YO10 3LU Tel:
Number of appliances tested: 1

APPLIANCE DETAILS

FLUE TESTS

INSPECTION DETAILS

	Location	Make and Model	Type	Flue Type OF/RS/FL	Operating pressure in mbar or heat input kW/h or Btu/h	Safety device(s) correct operation Yes/No/NA	Spillage test Pass/Fail/NA	Smoke pellet flue flow test Pass/Fail/NA	Initial combustion analyser reading	Final combustion analyser reading	Satisfactory termination Yes/No/NA	Flue visual condition Pass/Fail/NA	Adequate ventilation Yes/No	Landlord's appliance Yes/No/NA	Inspected Yes/No	Appliance Visual Check Yes/No	Appliance serviced Yes/No	Appliance Safe to Use Yes/No
1	Kitchen	Ideal Vogue C32	Boiler	RS	19.1	Yes	NA	NA	0000	0005	Yes	Pass	Yes	Yes	Yes	Yes	Yes	Yes
2																		
3																		
4																		
5																		

For appliances not owned by the landlord the recorded 'Appliance Safe to Use' response is based on a visual check for obvious defects only

Gas Installation
Pipework:

Satisfactory Visual
Inspection:

Yes ☒ No ☐

Emergency Control
Accessible:

Yes ☒ No ☐

Satisfactory Gas
Tightness Test:

Yes ☒ No ☐

Equipotential
Bonding Satisfactory:

Yes ☒ No ☐

GIVE DETAILS OF ANY FAULTS

RECTIFICATION WORK CARRIED OUT

WARNING
NOTICE ISSUED
Yes/No/NA

WARNING TAG or
LABEL FIXED
Yes/No/NA

1		
2		
3		
4		
5		

Approved Audible CO Alarms
Fitted & Located Correctly**:

Yes ☐ No ☐ N/A ☐

Are CO
Alarms in Date:

Yes ☐ No ☐ N/A ☐

Testing of CO
Alarms Satisfactory:

Yes ☐ No ☐ N/A ☐

Smoke/Heat Alarms
Located & Fitted correctly**:

Yes ☐ No ☐ N/A ☐

OTHER COMMENTS OR OBSERVATIONS

NEXT GAS
SAFETY
CHECK DUE
BEFORE:

23/05/26

ISSUED BY (GAS ENGINEER)

Print Name: J. Dawson
Licence No: 41304
Signed: [Signature]
Issue Date: 23/5/25

RECEIVED BY

Received By: N/A
Signed: [Signature]
Print Name: [Signature]
(Delete as applicable)
Tenant/Agent/Landlord/Home Owner
No one present
at time of visit ☒