



Landlord Gas Safety Record

Cert. No.

Simtec Plumbing And Heating

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998 section 26(9) and the Gas Industry Unsafe Situations Procedure.

Company / Installer

Engineer Deklan Simpson
 Company Simtec Plumbing And Heating
 Address Simtec Heating, The Raylor Centre
 James Street
 York
 Post Code YO103DW
 Tel No. 01904412109
 Gas Safe Reg 3916101
 ID Card No. 3916101

Job Address

Name
 Address Flat D 136
 Lawrence Street
 York
 Post Code YO10 3EB
 Tel. No

Customer / Landlord

Name
 Company Adam Bennetts
 Address 58
 Gillygate
 York
 Post Code YO31 7eq
 Tel. No 01904611611

Appliance Details				Inspection Details																
Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
									Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Boiler	Ideal	Logic Max Combi C24	RS	Yes	Yes	20.1	24	0.0011	169	9.1	0.0003	65	8.7	Yes	Yes	Yes	Pass	NA	Yes
2																				
3																				
4																				
5																				
6																				

Defects / Identified												Labels and Warning Notice Issued				CO Alarm(s)					
1																					
2																					
3																					
4																					
5																					
6																					

Emergency Control Accessible Yes Gas Tightness Satisfactory Yes

Gas Installation Pipework Visual Inspection Satisfactory Yes

Equipotential Bonding Yes

NEXT INSPECTION DUE BEFORE

Comments

Signatures

Issued by: Signed  Received Signed by:  Date

Print Name Print Name