



Landlord Gas Safety Record

Cert. No. 893

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998 section 26(9) and the Gas Industry Unsafe Situations Procedure.

Simtec Plumbing And Heating

Company / Installer		Job Address		Customer / Landlord	
Engineer	Deklan Simpson	Name		Name	
Company	Simtec Plumbing And Heating	Address	13	Company	Adam Bennetts
Address	Simtec Heating.The Raylor Centre		Norman Street	Address	58
	James Street		York		Gillygate
	York				York
		Post Code	YO10 3LH		
Post Code	YO103DW	Tel. No		Post Code	YO31 7eq
Tel No.	01904412109			Tel. No	01904611611
Gas Safe Reg	3916101				
ID Card No.	3916101				

Appliance Details						Inspection Details															
	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1		Boiler	Vokera	Unica 32 HE	RS	Yes	Yes	20.3	32	0.0010	81	8.3	NA	NA	NA	Yes	Yes	Yes	Pass	NA	Yes
2		Hob	Candy	Unknown	RS	Yes	Yes	NA	7	NA	NA	NA	NA	NA	NA	Yes	Yes	NA	NA	NA	Yes
3																					
4																					
5																					
6																					

Defects / Identified	Labels and Warning Notice Issued	CO Alarm(s)
1	NA	
2	NA	
3		CO Alarm(s) fitted Yes
4		
5		CO Alarm(s) tested and Satisfactory Pass
6		

Emergency Control Accessible Yes Gas Tightness Satisfactory Yes

Gas Installation Pipework Visual Inspection Satisfactory Yes

Equipotential Bonding Yes

Comments

Signatures		Received		Date	
Issued by:	Signed	Signed by:			28-Jul-2026
Print Name	Deklan Simpson	Print Name		NEXT INSPECTION DUE BEFORE	28-Jul-2027