

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

REGISTERED BUSINESS DETAILS

Reg No: 552856
Company: JEFFERSON FIRM LTD
Address: 116 CINTON WOOD CTR
Cinton on AWE. YOPA
Postcode: YO30 2TF
Tel: 01904 345733

INSPECTION/INSTALLATION ADDRESS

Name & Title: JEFFERSON POLISH
Address: 2 Greenway
Bodogor Hill
YO211

LANDLORD (OR AGENT) NAME & ADDRESS (if applicable)

Name & Title: JEFFERSON POLISH
Address: 1 DEWARIES REUS WAY
Bodogor Hill
Postcode: YO10 5HS
Tel: 07843426143
Number of appliances tested: 02

APPLIANCE DETAILS

	Location	Make and Model	Type	Flue Type Of/RS/FL	Operating pressure in mbar or heat input kW/h or Btu/h	Safety device(s) correct operation Yes/No/NA	Spillage test Pass/Fail/NA	Smoke pellet flue flow test Pass/Fail/NA	Initial combustion analyser reading	Final combustion analyser reading	Satisfactory termination condition Yes/No/NA	Flue visual condition Pass/Fail/NA	Adequate ventilation Yes/No	Landlord's appliance checked Yes/No/NA	Inspected Visual Check Yes/No	Appliance serviced Check Yes/No	Appliance serviced Yes/No	Appliance Safe to Use Yes/No
1	Boiler Room	Worcester Greenstar 24i Syre	Boiler	RS	19.1mb	Y/D	PA	NA	0.0001	0.0005	Y/D	Pass	Y/D	Y/D	Y/D	Y/D	Y/D	Y/D
2	Kitchen	Worcraft 6 burner Hob	HOB	FL		Y/D	PA	NA	—	—	PA	PA	Y/D	Y/D	Y/D	Y/D	Y/D	Y/D
3																		
4																		
5																		